



**GENERAL NOTES:**

- DESIGN SHALL MEET OR EXCEED EXCEED ASTM C-1227 SPECIFICATIONS
- 4000 PSI CONCRETE AT 28 DAYS
- ASTM A615, GRADE 60 REINFORCING
- BAR BENDING AND PLACEMENT PER ACI STANDARDS

**NOTE:**

APPROX WEIGHTS INCLUDING SLAB TOP & BOTTOM SECTION  
WEIGHT - 16,550 LBS  
CAPACITY - 3,010 GAL. (AT INLET)  
46.3 GALS PER INCH (APPROX)



9235 Main Street #1  
P.O. Box 507  
Needville, Texas, 77461  
1-888-331-5871

"Providing Concrete Environmental Solutions"

3000 GALLON  
PUMP TANK

NC-004-005

Scale: 1/4"=1'-0"  
\* All Dimensions subject to allowable specification tolerances.

Date: 03/17/19

Rev Date:

Approved By: \_\_\_\_\_ Date: \_\_\_\_\_